

CITY OF LOS ANGELES
CALIFORNIA

BOARD OF
BUILDING AND SAFETY
COMMISSIONERS

JAVIER NUNEZ
PRESIDENT

ELVIN W. MOON
VICE PRESIDENT

JOSELYN GEAGA-ROSENTHAL
LAUREL GILLETTE
GEORGE HOVAGUIMIAN



ERIC GARCETTI
MAYOR

DEPARTMENT OF
BUILDING AND SAFETY
201 NORTH FIGUEROA STREET
LOS ANGELES, CA 90012

OSAMA YOUNAN, P.E.
GENERAL MANAGER
SUPERINTENDENT OF BUILDING

JOHN WEIGHT
EXECUTIVE OFFICER

John Ramin
Pacific Plastics Inc.
111 S. Berry St.
Brea, CA 92821

RESEARCH REPORT: RR 5408
EFFECTIVE DATE: 03/01/2022
EXPIRATION DATE: 03/01/2023
Telephone: 714-990-9050

GENERAL APPROVAL - Renewal - "Pacific Cal" PVC pipes for water and sewer applications.
See attached list of approved sizes and classes/schedules.

DETAILS

These products are white, brown, and purple colored poly (vinyl chloride) (PVC) pipes made in various diameters and wall thicknesses. The purple colored pipe is for reclaimed water systems. Water piping is manufactured in accordance with Standards ASTM D1785 and/or ASTM D2241. Sewer piping is manufactured to ASTM D3034. These pipes are currently listed by NSF International.

The approval is subject to the following conditions:

1. These pipes are approved for use in locations where PVC pipes are approved in accordance with the Los Angeles Plumbing Code (LAPC), 2020 Edition.
2. This approval is not an authorization for use in fire protection systems. Separate approval or listing is required for PVC pipes to be installed in fire protection systems.
3. These PVC pipes are approved for the following applications:
 - a. Pipes labeled NSF-pw are approved for potable water applications.
 - b. Pipes labeled ASTM D1785 are Schedule 40 and 80 pipes approved for cold water applications.
 - c. Pipes labeled ASTM D2241 are SDR pipes approved for cold water applications.
 - d. Pipes labeled ASTM D3034 are Type PSM (SDR 35) pipes approved for sewage applications conveying non-pressure drainage.

4. Purple colored pipe shall only be used in reclaimed water systems. There shall be no direct

RR 5408

Page 1 of 4

Pacific Plastics Inc.
RE: PVC pipe

connections made between any potable water systems and any pipe carrying reclaimed water even with a backflow preventer.

5. Solvent cement complying with the Standard ASTM D2564 with an approved primer shall be used for joining these piping systems.
6. Pipes installed for cold water building supply applications shall be installed in accordance with the manufacturer's installation guidelines and the LAPC, 2020 Edition.
7. Pipes installed for sewer applications shall be installed in accordance with the manufacturer's installation guidelines and the LAPC, 2020 Edition.
8. Only approved fittings shall be used in the installation of these systems.
9. Piping for potable water shall be marked to include the following:
 - a. Manufacturer's name
 - b. Nominal pipe size
 - c. Type of Plastic, PVC1120
 - d. Schedule of piping
 - e. Pressure rating for water at 73°F
 - f. ASTM designation, ASTM D1785 or ASTM D2241
 - g. Production code with which the manufacturer can trace the year, month, day, shift, plant and extruder
 - h. Third party certification mark
10. Piping for sewer applications shall be marked to include the following:
 - a. Manufacturer's name
 - b. Nominal pipe size
 - c. The PVC cell classification
 - d. Standard dimension ratio followed by "PVC Sewer pipe"
 - e. "ASTM D3034"
 - f. Third party certification mark

DISCUSSION

The Mechanical Testing Laboratory reviewed recent test reports and current listing certificates. These products have been tested in accordance with ASTM Standards D1785, D2241 and/or D3034 and are listed by NSF International. The material and construction are equivalent to that prescribed by the Los Angeles Municipal Code in quality, strength, effectiveness, durability and safety.

For this General Approval to be valid on any individual construction project in the City of Los Angeles, an engineer or inspector of the Department of Building and Safety must make a

Pacific Plastics Inc.
RE: PVC pipe

determination that all conditions of the General Approval required to provide equivalency have been met in the case of each construction project under consideration.

This approval is granted under Sections 94.301.0, 94.313.5, 705.1.2 & 605.2.2, 94.603.0, 94.604.0, 94.701.0 and 94.715.0 of the LAPC, 2020 Edition.

Approved by:



Irene Pool
Mechanical Testing Laboratory
Permit and Engineering Bureau

Pacific Plastics Inc.
RE: PVC pipe

Plastic Plastics Inc.
RR-5408
List of Approved Pipe Classes/Schedules

PVC pipes for sewer applications:

Type PSM (SDR 35) - Bell end or gasketed pipe - in sizes 4", 6", 8", 10", 12", and 15"

Note: This pipe is also available factory perforated and may be installed where perforated PVC pipe is allowed by LAPC, 2020 Edition.

PVC pipes for cold water applications:

Plain End

Schedule 40 - ½", ¾", 1", 1-¼", 1-½", 2", 2-½", 3", 4" and 6"

Schedule 80 - ½", ¾", 1", 1-¼", 1-½", 2", 2-½", 3", 4" and 6"

Class 160 (SDR 26) - 1-¼", 1-½", 2", 2-½", 3" and 4"

Class 200 (SDR 21) - ¾", 1", 1-¼", 1-½", 2", 2-½", 3", and 4"

Class 315 (SDR 13.5) ½", 2", 3" and 4"